

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F&DFS/MS/School/2019/SZ/1781

Dated: 18-10-22

FIRE SAFETY CERTIFICATE

Certified that the Babu Khem Chand Advocate Memorial Public School located at Street No. 56, Hind 60 Feet Road, Sabzi Mandi, Molarband Extn, Badarpur, New Delhi-110044 Comprised of ground plus one upper floor was issued NOC by this department vide letter No. F&DFS/MS/School/2019/SZ/1781 Dated 17/09/2019. The premises was re-inspection by the officer concerned by this department on 12/10/2022 in the presence of Sh. Devender Choudhary (Manager) of the school and found that fire prevention and fire safety requirements have deemed complied in accordance with Circular No. 262-263 dated 17/01/2015 issued by Education Directorate, Govt. of NCT of Delhi, Old Secretariat, New Delhi and that the premises fit for occupancy class Education Building, Group-B as above with effect from the date of the issue of this certificate for the period of three years subject to compliance of conditions mentioned below.

Issued on 18-10-22 at New Delhi by


(Sunil Choudhary)
Dy. Chief Fire Officer
Tel. 011-26189168


Copy to :-

1. The Principal, Babu Khem Chand Advocate Memorial Public School, Street No. 56, Hind 60 Feet Road, Sabzi Mandi, Molarband Extn, Badarpur, New Delhi-110044
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for the renewal of this Fire Safety Certificate to the Director in the form 'J' (sub rule (1) of rule 37) along with the copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

Babu Khem Chand Adv.
Memorial Public Sch.
(B.K.C.A.M.P.S.)
St. No. 56, Hind 60 Ft. Road,
Molarband Extn., New Delhi-11


18/10/22